

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7270-1477:114 Page 1 of 1

**CATEGORY:** Heat Detector

**LISTEE:** Mircom Technologies, 8111 Jane Street, Vaughan, Ontario L4K 4L7 Canada  
Contact: \*Mara Cherubin (888) 660-4655 Fax (888) 660-4113

**DESIGN:** Models MIX-5251P, -5251B (fixed temperature) and MIX-5251RP, -5251RB (fixed temperature with Rate-of-Rise) electronic heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 135<sup>0</sup> F fixed temperature

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings, and UL Label.

**APPROVAL:** Listed as heat detectors for use with \*Models MIX-B501BH or MIX-B210LP bases (CSFM Listing No. 7300-1477:116) and separately listed compatible fire alarm control units. Refer to listee's Installation Instructions Manual for details.

**XLF:** 7270-1209:193

\*Rev. 04-18-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 18, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**